



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-7301 [REDACTED]
Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Distributor <i>Vertreiber</i>	PCC GmbH Düsseldorfer Straße 15, D-71332 Waiblingen
Product Category <i>Produktart</i>	stainless tubes: stainless steel tube (7301)
Product Description <i>Produktbezeichnung</i>	tube made of stainless steel for the drinking water installation, materials: 1.4401; 1.4404; 1.4521
Model <i>Modell</i>	PRESS-INOX
Test Reports <i>Prüfberichte</i>	laboratory control test: 6508162-2 from 15.11.2021 (TSZ) supplement test: 2261161-1 from 04.02.2015 (TSZ) type testing: 600011056 from 21.12.2012 (TSZ) supplement test: 1774219 from 25.05.2012 (TSZ) supplement test: 1547093 from 07.09.2010 (TSZ) type testing: 983498 from 18.06.2007 (TSZ)
Test Basis <i>Prüfgrundlagen</i>	DVGW GW 541 (01.10.2004) UBA BWGL-Metalle (14.05.2020)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	18.06.2027 / 22-0258-WNV

70008-04-A-DE

21.04.2022 LE D-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
Typ	Technische Daten	Bemerkungen
PRESS-INOX	manufacturing group: 12,0 up to 108,0 mm	according to GW 541, table 3

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

tested diameters according to GW 541, table 3, materials: 1.4401; 1.4404

12,0 mm; 15,0 mm; 18,0 mm; 22,0 mm; 28,0 mm; 35,0 mm; 42,0 mm; 54,0 mm; 76,1 mm; 88,9 mm; 108,0 mm

tested diameters according to GW 541, table 3, material: 1.4521

12,0 mm; 15,0 mm; 18,0 mm; 22,0 mm; 28,0 mm; 35,0 mm; 42,0 mm; 54,0 mm